



**HILLTOWN TOWNSHIP  
BUCKS COUNTY, PENNSYLVANIA  
RESOLUTION #2024-012**

**A RESOLUTION OF THE BOARD OF SUPERVISORS OF HILLTOWN  
TOWNSHIP, BUCKS COUNTY ADOPTING LOCAL LIMITS TO REGULATE  
DISCHARGES OF PROCESS WASTEWATER POLLUTANTS TO THE  
HATFIELD TOWNSHIP MUNICIPAL AUTHORITY WASTEWATER  
TREATMENT PLANT**

---

**WHEREAS**, the Clean Water Act, 33 U.S.C. § 1251, et seq., and its implementing regulations (40 C.F.R. § 403.5) provide for the development of local limits by Publicly Owned Treatment Works (“POTWs”); and

**WHEREAS**, the Hatfield Township Municipal Authority’s treatment plant (“HTMA Plant”) located in Colmar, Pennsylvania is considered a POTW; and

**WHEREAS**, the Hatfield Township Municipal Authority (“HTMA”) and Hilltown Township (the “Township”) entered into an Inter-jurisdictional Agreement on February 26, 2001, in which local limits were adopted for users of the HTMA Plant that are located within the Township; and

**WHEREAS**, subsequent to the February 26, 2001 Inter-jurisdictional Agreement, HTMA has adopted, pursuant to HTMA Resolution 2024-1, a revised list of local limits; and

**WHEREAS**, the revised local limits adopted by HTMA are provided in Exhibit “A” attached hereto, and will become effective upon final approval by the United States Environmental Protection Agency.

**NOW, THEREFORE, BE IT RESOLVED** as follows:


1. The Township hereby specifically adopts the Local Limits in Exhibit "A" for users of the HMTA Plant that are located within the Township.
2. No user of the HTMA Plant shall discharge process wastewater local limits pollutants in excess of the indicated concentrates in Exhibit "A" without permit or other approval from HTMA.
3. The Township acknowledges that HTMA reserves the right to change or amend its list of Local Limits at any time and if HTMA changes or amends its list of Local Limits, the Township shall execute an addendum to the Resolution to reflect such change or amendment.
4. All prior resolutions and/or agreements, or parts thereof, inconsistent with this Resolution are hereby repealed. However, all terms and conditions of the Inter-jurisdictional Agreement dated February 26, 2001 by and between HTMA and the Township that are not inconsistent with this Resolution shall remain in effect.
5. This Resolution shall become effective this 22<sup>nd</sup> day of April, 2024.

**HILLTOWN BOARD OF SUPERVISORS**

  
Caleb Torrice Chairman

  
James C. Groff, Vice-Chairman

  
Joseph Metzinger, Supervisor

ATTEST:   
Marianne Egan,  
Township Asst. Secretary

## EXHIBIT – “A”

### HTMA – Local Limits 2023

Pollutant	Local Limits* Default Concentration- Mg/l	MAILS Maximum Allowable Industrial Loadings – (lbs./day)
Arsenic	0.02	1.09
Cadmium	0.01	0.23
Chromium	2.00	11.42
Copper	2.00	15.58
Lead	0.20	2.21
Mercury	0.0005	0.0024
Nickel	0.25	8.22
Silver	0.30	2.32
Zinc	2.00	20.64
Bis-(2-Ethylhexyl)Phthalate	0.20	0.65
Methylene Chloride	0.20	4.70
Phenolics-total	2.00	18.66

*\*- Note: Local Limits concentrations represent “end-of-process” daily average default allocations for the specified pollutants applicable to all industrial and commercial users (IUs) discharging process wastewater to HTMA for disposal. No IU shall discharge process wastewater pollutants in excess of the concentrations listed above without written permit from HTMA.*